

SUMMARY OF AS/NZS 4284 Testing of Building Facade for

FLASHCLAD FLASHING SYSTEM AND DUALBORD AND EUROBORD CLADDINGS

**Ultimate Limit Pressure Testing**

Pass - at +4.5kPa and - 4.5 kPa

Windspeed - 312 kph

**Seal Degradation Testing** (Additional to AS/NZS 4284 Testing)

Pass- No water penetration and RAB remaining dry.

**For full AS/NZS 4284 Report please email [info@flashclad.co.nz](mailto:info@flashclad.co.nz)**